

## **Title 19**

### **Part 7: State Fire Marshal**

#### **Chapter 8: General L.C. Gas Regulations**

##### **Rule 8.01** Transfer of Liquids.

When an LP-Gas container is used for motor fuel, farm implements, portable containers or similar service and cannot be serviced due to excessive vapor pressure in the fuel container, vapor pressure may be reduced to facilitate fueling by venting to the atmosphere, provided the liquid transfer is located not less than 50 feet from the nearest important building and in an open area without undue hazard to any building or surrounding property and there is no open flame or other source of ignition in the area. Passenger-carrying vehicles shall not be fueled in this manner while passengers are on board.

Source: Miss. Code Ann. §§75-57-1. et sec. (Rev. 2009)

##### **Rule 8.02** Appliances.

**8.02.1** Room Heaters. Unvented room heaters may be installed in residential sleeping quarters and bathrooms provided the aggregate input rating does not exceed 20 BTU's per hour per cubic foot of room or space in which it is installed.

Source: Miss. Code Ann. §§75-57-1. et sec. (Rev. 2009)

**8.02.2** Heating Appliances In Stationary Mobile Homes. Vented or Non-vented type circulating room heaters may be installed in stationary mobile homes for use with LP-Gas as follows:

- A. The appliance must be listed for use with LP-Gas by the American Gas Association or other nationally recognized testing laboratory.
- B. The appliance must be installed in accordance with NFPA-54 provisions for combustion and circulating air.
- C. A clayback heater cannot be used; however a heater with a cool-type cabinet may be used.

Source: Miss. Code Ann. §§75-57-1. et sec. (Rev. 2009)

##### **Rule 8.03** Effective Date

This regulation will become effective thirty (30) days after the Final Rule is filed.

Source: Miss. Code Ann. §25-43-3.113. et seq. (Rev. 2010)